



BANGALORE WATER SUPPLY AND SEWERAGE BOARD

Office of the CE (Project)

Cauvery Bhavan III Floor, Bangalore 560009

No. BWSSB/CE(P)/ACE (Cst-DCW)/ **1305** /2025-26 Dt: **16** /10/2025

Sub: Work of dismantling of existing old SSM GLR and construction of new 20ML RCC GLR at CLR service station premises under AEESE-1 sub-division-Pre-bid query reply.

Ref: 1. NO.BWSSB/CE (P)/ACE (Cst-DCW)/1241/2025-25 Dtd: 29.09.2025.
2. Tender INDENT No. BWSSB/2025-26/OW/WORK_INDENT2467

With reference to the above subject, BWSSB response for the Pre bid query received during the pre-bid meeting held on 10.10.2025 is as follows:

Sl No.	Particulars	Queries/requests	BWSSB Response
1.	Drawings	Request you to enclose existing layout drawings & proposed layout drawings.	Enclosed.
2.	General	Since the existing 20 ML GLR is constructed with size stone masonry, kindly clarify the ownership of the dismantled size stone.	The ownership of dismantled size stone will be with BWSSB. This has to be auctioned as per BWSSB procedure by the contractor.
3.	Conditions of Contract 18 18.2 The contractor shall be responsible for the design of Temporary Works	Kindly clarify the scope of design and drawings for the proposed 20 ML GLR. Please confirm whether the construction drawings will be provided by the consultant or are to be prepared by the contractor. If the design is under the contractor's scope, an additional provision for design shall be included. Kindly Clarify.	All structural design of item rate contract is by BWSSB. However, as per SCC clause 36, 6 set hard copies of these drawings need to be submitted by contractor for approval as per client design soft copy.
4.	Disposal of unserviceable materials.	Kindly clarify the lead distance for the disposal of unserviceable materials. Since the proposed site is located in the heart of the city, the	Tender condition prevails.

		disposal distance is expected to exceed 25 km. Therefore, an additional item for the same may please be included. Kindly clarify.	
5.	General	If the existing PCC /raft to be retained, an additional item for conducting a necessary laboratory tests shall be included for designing the proposed GLR. Kindly clarify.	Laboratory tests shall be conducted for designing the proposed GLR and no additional items or payment will be made.
6	General	As the existing GLR is presently in service, we request clarification on whether the contractor must ensure continuous water supply to the existing network after dismantling the GLR, or if the supply can be temporarily discontinued. In case uninterrupted supply is to be maintained, please confirm if the corresponding items have been considered in the uploaded BOQ.	Internal arrangements are already made to ensure water supply to the command areas coming under this GLR.

All other terms and conditions remain the same.


Chief Engineer' (Project)
BWSSB